


SIX TIER LOCKER

Date Issued 01-17



WIDTH	DEPTH	HEIGHT WITH LEGS
12	12	78
12	15	
12	18	
15	15	
15	18	

WIDTH	DEPTH	HEIGHT – NO LEGS
12	12	72
12	15	
12	18	
15	15	
15	18	

THIS MANUFACTURER RESERVES THE RIGHT TO MAKE CHANGES IN DESIGN OR DIMENSIONS WITHOUT FORMAL NOTICE

SPECIFICATION

Material – All major steel parts shall be of mild cold rolled commercial quality steel.

Finish – All material shall be power washed and phosphate treated for maximum finish color adhesion. All components shall be finished with a hybrid epoxy/polyester powder, electrostatically applied to ensure uniform thickness and baked to cure.

Construction – All lockers shall be built on a unit principle with common intermediate uprights separating units.

Door Frames – Shall be 16 gauge formed in a channel shape. Vertical members shall have additional flange to provide a continuous door strike. Cross frame members shall also be 16 gauge channel shaped.

Doors – Shall be 14 gauge, channel shaped on both the lock and hinge side, with angle formations across the top and bottom. Locker doors shall have a 16 gauge full height reinforcement channel.

Body – Backs shall be 18 gauge; all other body parts shall be 16 gauge. Bolt spacing shall not exceed 9" o.c.

Hinges – Shall be full length 16 gauge continuous piano type riveted to both door and frame.

Handles – Shall be one-piece 20 gauge deep drawn stainless steel cup designed to accommodate locks.

Latching – Lockers shall have an 11 gauge frame hook with anti pry feature secured to the frame. The frame hook shall have a padlock hasp protruding through the recessed handle. A rubber silencer shall be firmly secured to the frame at each latch hook.

Number Plates – Each locker shall have a polished aluminum number plate riveted to door frame with black numerals 3/8" high.

Color – Doors, frames and all body parts shall be finished in same color.

Assembly – Factory assembled lockers shall be riveted. Knocked Down “KD” lockers shall be supplied with nuts and bolts unless otherwise specified.

Installation – Lockers shall be installed in accordance with ASI Storage Solution’s installation instructions and shall be level and plumb with flush surfaces and rigid attachment to anchoring surfaces.