

ELKAY PRO FILTRATION™ SEDIMENT PREFILTER

Manual & Performance Data Sheet



STOCK UP ON ELKAY PRO FILTRATION™

Elkay Pro Filtration bottle filling stations are compatible only with Elkay Pro Filtration filters.

Replacing filters as recommended gives the added assurance of serving cleaner, safer water.

FOR USE AS STAGE 1 FILTRATION WITH FLP4, FL6 OR FL10



1-800-834-4816



elkay.com/filtration

RECOMMENDED USE CONDITIONS

System Model	Replacement Element	Working Pressure	Operating Temperature	Flow Rate	Capacity
EWFPRO	FSR5	Max pressure 100 psi (689 kPa) (7.0 Kg/cm2)	40 – 100° F (5 – 38° C)	1.5 GPM (5.7 LPM)	Variable, depending on local water quality 1 Year Maximum

This system has been certified by IAPMO R&T to NSF/ANSI 42 for material safety and structural integrity only, and to NSF/ANSI/CAN 372 for lead free compliance.



This prefilter helps filter out larger dirt particles, sand and other sediment, helping to extend the life of the primary filter.

Performance will vary depending on local water conditions. While testing was performed under standard laboratory conditions, actual performance may vary. Replace prefilter when water flow becomes extremely low. Filter installation and usage must comply with applicable local and state regulations.

IMPORTANT NOTICE: Read this Performance Data Sheet and compare the capabilities of this unit with your actual water treatment needs. It is recommended that, before purchasing a water treatment unit, you have your water supply tested to determine your actual water treatment needs. **PLEASE NOTE:** If this device is not maintained and operated as specified in the owner's manual, there is a risk of exposure to contaminants.

PLEASE NOTE: For use on cold water line only. Do not allow installed filter to freeze.

Limited Warranty


This product is warranted to be free from defects in material and workmanship for a period of one year from the date of installation. Warranty is limited to repair or replacement of defective component.

⚠ WARNING: Cancer and Reproductive Harm – www.P65Warnings.ca.gov


⚠ ADVERTENCIA: Cáncer y daño reproductivo – www.P65Warnings.ca.gov

⚠ AVERTISSEMENT: Cancer et effets néfastes sur la reproduction – www.P65Warnings.ca.gov

FILTER REPLACEMENT INSTRUCTIONS




Turn off water supply; dispense water to relieve pressure; turn off unit power.



Turn used filter(s) 1/4 rotation to remove from filter head.




Remove cap from new filter and use to seal used filter.



Hold filter as shown above. Firmly insert into filter head. Turn filter 1/4 rotation until it locks into place and the front label is clearly visible. Repeat for second filter if equipped.



Turn on unit power. The display will show a countdown to the start of the filter flush. Turn on the water supply.



After the automatic filter flush is completed, the three filter status LEDs will reset to blue.

Patent zurnelkay.com/patents